

# FUNCTIONAL SAFETY CERTIFICATE

CERTIFICATO – ZERTIFIKAT – CERTIFICADO – CERTIFICAT

The product:

*FS Universal Monitoring Module  
(UMM<sub>FS</sub>)*

Manufactured by:

*Brüel & Kjær Vibro America Inc.  
(part of Brüel & Kjær Vibro, a Spectris Company)  
1100 Mark Circle,  
Gardnerville, NV 89410, United States*

suitable for the following safety function(s):

Monitoring module for vibration applications in industrial machinery and process safety.

has been assessed per the relevant requirements of

**IEC 61508:2010 Parts 1 to 3**

and meets the requirements providing the following:

## Systematic Capability:

The compliance with the requirements for the avoidance of systematic faults and the requirements for the control of systematic faults have been achieved following the compliance route 1<sub>s</sub>.

SC 2

## Hardware Safety Integrity:

The constraints on hardware safety integrity have been verified in order to achieve a sufficiently robust architecture taking into account the level of element and subsystem complexity following the compliance route 1<sub>H</sub>.

Type  
B

## Random Safety Integrity:

The estimated safety integrity, for each safety function, due to random hardware safe and dangerous failures rates (excluding "no part" and "no effect" contribution).


See  
page  
2

The architectural constraints and the effects of random failures (PFH/PFD<sub>AVG</sub>) must be verified for each specific application and safety function implemented by the E/E/PE safety-related system.

Certified by:

**BYHON**

BYHON Certification Director:



Rosati Francesco

CERTIFICATE No:

**BKVA-UMMFS-PSE-B01**

Revision: A

Issued:

October 31<sup>st</sup>, 2023

Valid until:

October 30<sup>th</sup>, 2026

The owner of a valid certificate for an assessed product is authorized to affix the following mark and relative ID number, to all recognized devices which are identical to the product assessed.

**BYHON**  
**SIL** ✓

**ID.N° 117223PS04A**



#8914  
ISO/IEC 17065  
Product Certification Body

The design of each Safety Instrumented Function (SIF) shall meet the requirements listed in the reference standards that shall be selected by taking into account the specific application. Specific activities necessary to investigate and reach a judgment on the adequacy of the functional safety achieved by the E/E/PE safety-related system or compliant items (elements/subsystems) has been conducted by an independent assessor.

The following failure rates data shall be used to the PFH/PFD<sub>AVG</sub> estimation, taking into consideration all parameters such as redundancy, architectural constraints, diagnostic capability, also introduced by the whole system, including the considerations about the proof test and its effectiveness, mean time of restoration, up to the maintenance capability and its minimum characteristics.

**FS Universal Monitoring Module (UMM<sub>FS</sub>) failure rates**

|  | $\lambda_s$ | $\lambda_{DU}$ | $\lambda_{DD}$ | $\lambda_{RES}$ | Type     |
|--|-------------|----------------|----------------|-----------------|----------|
| <b>UMM<sub>FS</sub><br/>(Common Board Portion)</b> | <b>744</b>  | <b>345</b>     | <b>179</b>     | <b>351</b>      | <b>B</b> |
| <b>INPUT CHANNEL<br/>(Common to all types)</b>     | <b>144</b>  | <b>72</b>      | <b>0</b>       | <b>19</b>       | <b>A</b> |
| <b>INPUT CHANNEL<br/>(Proximitör)</b>              | <b>82</b>   | <b>39</b>      | <b>0</b>       | <b>30</b>       | <b>A</b> |
| <b>INPUT CHANNEL<br/>(IEPE Probe)</b>              | <b>22</b>   | <b>12</b>      | <b>0</b>       | <b>74</b>       | <b>A</b> |
| <b>INPUT CHANNEL<br/>(Moving Coil)</b>             | <b>1,3</b>  | <b>0,6</b>     | <b>0</b>       | <b>0,6</b>      | <b>A</b> |
| <b>INPUT CHANNEL<br/>(2-Wire 4-20mA)</b>           | <b>1,2</b>  | <b>0,6</b>     | <b>0</b>       | <b>0,6</b>      | <b>A</b> |
| <b>OUTPUT CHANNEL<br/>(Onboard Relay)</b>          | <b>60</b>   | <b>33</b>      | <b>2,4</b>     | <b>7</b>        | <b>A</b> |

Note:

- UMM<sub>FS</sub> order options are listed in the document S1077787.002.
- The  $\lambda_{RES}$  (RESIDUAL) failure rates includes the NO PART and NO EFFECT failure rates.
- All failure rates are in FIT (Failure In Time 1 FIT = 1 failure / 10<sup>9</sup> hours).
- The product is capable to be used in Safety Instrumented Systems (SIS) when properly designed into a Safety Instrumented Function (SIF) and configured according to the Safety Manual. The product is SIL 1 capable in simplex configuration and SIL 2 capable in case of redundancy.

UMM<sub>FS</sub> firmware and MPS configuration software release covered by the present certificate are respectively:

- UMM<sub>FS</sub> firmware release: 7.10.9103
- MPS Configuration software release: 7.15.0905

The prescriptions contained in the safety manual C107577.002 shall be followed.

CERTIFICATE No:  
**BKVA-UMMFS-PSE-B01**

Revision: A

Issued:  
October 31<sup>st</sup>, 2023

Valid until:  
**October 30<sup>th</sup>, 2026**

The Functional Safety  
Assessment report no.

**20-BKV-UMMFS-FSA-03**

dated:  
October 31<sup>st</sup>, 2023

is an integral part of this  
certificate



Mod\_12\_CB Rev05

BYHON  
Via Lepanto 23, 59100  
Prato (PO)  
ITALY

\*The Certificate shall be reproduced  
only in its original entirety.