

FUNCTIONAL SAFETY CERTIFICATE

CERTIFICATO – ZERTIFIKAT – CERTIFICADO – CERTIFICAT

The product:

Industrial Seismic Accelerometer SA6200A

Manufactured by:

*Metrix Instruments Co.
8824 Fallbrook Dr. Houston, TX 77064
United States of America*

suitable for the following safety function(s):

To monitor constantly the machine vibration level at the portion where the device is installed and to provide an analog voltage output proportional to the measured vibration (mV/g)

has been assessed per the relevant requirements of

IEC 61508:2010 Parts 1 to 7

and meets the requirements providing the following:

Systematic Capability:

The compliance with the requirements for the avoidance of systematic faults and the requirements for the control of systematic faults have been achieved following the compliance route 1_S.

SC 3

Hardware Safety Integrity:

The constraints on hardware safety integrity have been verified in order to achieve a sufficiently robust architecture taking into account the level of element and subsystem complexity following the compliance route 1_H.

Type
A

Random Safety Integrity:

The estimated safety integrity, for each safety function, due to random hardware safe and dangerous failures rates (excluding "no part" and "no effect" contribution).

See
page
2

The architectural constraints and the effects of random failures (PFH/PFD_{AVG}) must be verified for each specific application and safety function implemented by the E/E/PE safety-related system.

Certified by:

BYHON

BYHON Certification Director:


Rosati Francesco

CERTIFICATE No:
MTXI-6200A-ENS-E01
Revision: A

Issued:
June 15th, 2022

Valid until:
June 14th, 2025

The owner of a valid certificate for an assessed product is authorized to affix the following mark and relative ID number, to all recognized devices which are identical to the product assessed.

BYHON
SIL ✓

ID.N° 010522EN06A



#8914
ISO/IEC 17065
Product Certification Body

The design of each Safety Instrumented Function (SIF) shall meet the requirements listed in the reference standards that shall be selected by taking into account the specific application. Specific activities necessary to investigate and reach a judgment on the adequacy of the functional safety achieved by the E/E/PE safety-related system or compliant items (elements/subsystems) has been conducted by an independent assessor.

The following failure rates data shall be used to the PFH/PFD_{AVG} estimation, taking into consideration all parameters such as redundancy, architectural constraints, diagnostic capability, also introduced by the whole system, including the considerations about the proof test and its effectiveness, mean time of restoration, up to the maintenance capability and its minimum characteristics.

Device failure rates

Configuration	λ_s	λ_{DU}	λ_{DD}
With external out-of-range diagnostics	-	64	102
Without external diagnostics	-	166	-

Note:

- All failure rates are in FIT (Failure In Time 1 FIT = 1 failure / 10⁹ hours).

The prescriptions contained in the safety manual no. QP064-45 shall be followed.

CERTIFICATE NO:
MTXI-6200A-ENS-E01

Revision: A

Issued:
June 15th, 2022

Valid until:
June 14th, 2025

The Functional Safety
Assessment report no.

22-MTX-6200A-FSA-01

dated:
June 14th, 2022

is an integral part of this
certificate



Mod_12_CB Rev03

BYHON
Via Lepanto 23, 59100
Prato (PO)
ITALY