

FUNCTIONAL SAFETY CERTIFICATE

CERTIFICATO – ZERTIFIKAT – CERTIFICADO – CERTIFICAT

The product:

*FS Temperature Monitoring Module
(TMM_{FS})*

Manufactured by:

*Brüel & Kjær Vibro America Inc.
(part of Brüel & Kjær Vibro, a Spectris Company)
1100 Mark Circle,
Gardnerville, NV 89410, United States*

suitable for the following safety function(s):

Monitoring module for temperature detection in industrial machinery
and process safety

has been assessed per the relevant requirements of

IEC 61508:2010 Parts 1 to 3

and meets the requirements providing the following:

Systematic Capability:

The compliance with the requirements for the avoidance of systematic faults and the requirements for the control of systematic faults have been achieved following the compliance Route 1_S.

SC 2

Hardware Safety Integrity:

The constraints on hardware safety integrity have been verified in order to achieve a sufficiently robust architecture taking into account the level of element and subsystem complexity following the compliance Route 1_H.

Type
B

Random Safety Integrity:

The estimated safety integrity, for each safety function, due to random hardware safe and dangerous failures rates (excluding "no part" and "no effect" contribution).

See
page
2

The architectural constraints and the effects of random failures (PFH/PFD_{AVG}) must be verified for each specific application and safety function implemented by the E/E/PE safety-related system.

Certified by:

BYHON

BYHON Certification Director:

Rosati Francesco

CERTIFICATE No.:
BKVA-TMMFS-PSE-B02

Issued:
July 22nd, 2026

Valid until:
October 30th, 2026

The owner of a valid certificate for an assessed product is authorized to affix the following mark to all recognized devices which are identical to the product assessed.

BYHON
SIL ✓



ANSI National Accreditation Board
ACCREDITED

ISO/IEC 17065

**PRODUCT CERTIFICATION
BODY**
#8914

*The Certificate shall be reproduced only in its original entirety

The design of each Safety Instrumented Function (SIF) shall meet the requirements listed in the reference standards that shall be selected by taking into account the specific application. Specific activities necessary to investigate and reach a judgment on the adequacy of the functional safety achieved by the E/E/PE safety-related system or compliant items (elements/subsystems) has been conducted by an independent assessor.

The following failure rates data shall be used to the PFH/PFD_{AVG} estimation, taking into consideration all parameters such as redundancy, architectural constraints, diagnostic capability, also introduced by the whole system, including the considerations about the proof test and its effectiveness, mean time of restoration, up to the maintenance capability and its minimum characteristics.

FS Temperature Monitoring Module (TMM_{FS}) failure rates

	λ_s	λ_{DU}	λ_{DD}	Type
TMM _{FS} (Common Board Portion)	663	268	105	B
INPUT CHANNEL (Redundant*)	124	76	50	A
OUTPUT CHANNEL (Onboard Relay)	60	33	2.4	A

Note:

- Redundancy shall be considered between channels 1, 2 and 4 with channels 3, 5 and 6.
- TMM_{FS} order options are listed in the document S1077788.002.
- All failure rates are in FIT (Failure In Time 1 FIT = 1 failure / 10⁹ hours).
- The product is capable of being used in Safety Instrumented Systems (SIS) when properly designed into a Safety Instrumented Function (SIF) and configured according to the Safety Manual. The product is SIL 1 capable in simplex configuration and SIL 2 capable in case of redundancy.

TMM_{FS} firmware and MPS Configuration software release covered by the present certificate are respectively:

- TMM_{FS} firmware release: 8.03.9000
- MPS Configuration software release: 8.7.181.0

The prescriptions contained in the safety manual C107576.002 shall be followed.

CERTIFICATE No.:
BKVA-TMMFS-PSE-B02

Issued:
July 22nd, 2026

Valid until:
October 30th, 2026

The Functional Safety
Assessment report no.

23-BKV-TMMFS-FSA-02

dated:
July 22nd, 2026

is an integral part of this
certificate



Mod_12_CB Rev09

BYHON
Via Lepanto 23, 59100
Prato (PO)
ITALY

*The Certificate shall be reproduced only in its original entirety.