

# FUNCTIONAL SAFETY CERTIFICATE

CERTIFICATO – ZERTIFIKAT – CERTIFICADO – CERTIFICAT

The product:

**Emergency Stop Pushbuttons**

Manufactured by:

**Rockwell Automation, Inc.**  
1201 South 2<sup>nd</sup> Street, Milwaukee  
WI 53024  
USA

suitable for the following safety function(s):

Open the normally closed emergency contacts allowing the downstream emergency devices to block the machine/unit

has been assessed per the relevant requirements of

**IEC 61508:2010 Parts 1 to 2**

and meets the requirements providing the following:

## Systematic Capability:

The compliance with the requirements for the avoidance of systematic faults and the requirements for the control of systematic faults have been achieved following the compliance route 1<sub>S</sub>.

SC 3

## Hardware Safety Integrity:

The constraints on hardware safety integrity have been verified in order to achieve a sufficiently robust architecture taking into account the level of element and subsystem complexity following the compliance route 1<sub>H</sub>.

Type  
A

## Random Safety Integrity:

The estimated safety integrity, for each safety function, due to random hardware safe and dangerous failures rates (excluding "no part" and "no effect" contribution).

See  
page  
2

The architectural constraints and the effects of random failures (PFH/PFD<sub>AVG</sub>) must be verified for each specific application and safety function implemented by the E/E/PE safety-related system.

Certified by:

**BYHON**

BYHON Certification Director:

  
Rosati Francesco

CERTIFICATE No:  
RCKW-PUSHB- ENS-E01

Revision: A

Issued:  
August 2<sup>nd</sup>, 2023

Valid until:  
February 3<sup>rd</sup>, 2025

The owner of a valid certificate for an assessed product is authorized to affix the following mark and relative ID number, to all recognized devices which are identical to the product assessed.

**BYHON**  
**SIL** ✓

**ID.N° 158623EN01A**



#8914  
ISO/IEC 17065  
Product Certification Body

The design of each Safety Instrumented Function (SIF) shall meet the requirements listed in the reference standards that shall be selected by taking into account the specific application. Specific activities necessary to investigate and reach a judgment on the adequacy of the functional safety achieved by the E/E/PE safety-related system or compliant items (elements/subsystems) has been conducted by an independent assessor.

The following failure rates data shall be used to the PFH/PFD<sub>AVG</sub> estimation, taking into consideration all parameters such as redundancy, architectural constraints, diagnostic capability, also introduced by the whole system, including the considerations about the proof test and its effectiveness, mean time of restoration, up to the maintenance capability and its minimum characteristics.

**Failure rates for Emergency Stop Pushbuttons**

Code	$\lambda_s$	$\lambda_{DU}$	$\lambda_{DD}$
26149501	42	4	0
26149517	42	4	0
26149518	42	4	0
26149505	42	4	0
26149506	42	4	0
26149512	42	4	0

Notes:

- All failure rates are in FIT (Failure In Time 1 FIT = 1 failure / 10<sup>9</sup> hours).
- Each configuration can be used up to SIL 3 application.

The prescriptions contained in the manual 6300-UM002A-EN-P shall be followed.

CERTIFICATE NO:  
**RCKW-PUSHB- ENS-E01**

Revision: A

Issued:  
August 2<sup>nd</sup>, 2023

Valid until:  
**February 3<sup>rd</sup>, 2025**

The Functional Safety  
Assessment report no.

**23-RKW-PUSHB-FSA-01**

dated:  
July 31<sup>st</sup>, 2023

is an integral part of this  
certificate



Mod\_12\_CB Rev05

BYHON  
Via Lepanto 23, 59100  
Prato (PO)  
ITALY

\*The Certificate shall be reproduced  
only in its original entirety.